



MUNICIPAL COUNCIL, ARVI, DIST. WARDHA

E-mail : ngarparishadarvi@gmail.com

Phone No.:- 07157-224251



No./MCA/S.D./ 165 /2024

Date : 19 / 05 /2024

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by Sanitary Inspector & Mechanical & Environmental Engineer from Municipal Council, Arvi, Dist. Wardha inspected the Mount Carmel Convent School, Adegaon, Th. Arvi, Dist. Wardha on 13/05/2024 and found that the Mount Carmel Convent School, Adegaon has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central / State / U.T. Govt.

The above valid for a period of 14/05/2024 to 13/05/2025. (One Year)

Siran

(Dr. Kiran Sukalwad)
Chief Officer,
Municipal Council, Arvi.

To,

✓ Mount Carmel Convent School,
Adegaon, Th. Arvi,
Dist. Wardha



Mini

MANAGER

MOUNT CARMEL CONVENT SCHOOL
ADEGAON, TH. ARVI, DIST. WARDHA (M.S)-4422

Namt

PRINCIPAL

MOUNT CARMEL CONVENT SCHOOL
ADEGAON, TH. ARVI, DIST. WARDHA (M.S)-442201



**OFFICE OF THE SENIOR GEOLOGIST,
GROUNDWATER SURVEYS AND DEVELOPMENT AGENCY, WARDHA
WATER ANALYSIS TESTING REPORT**

Ref :- Lab Test Report No.:9/SDL/GSDA/Arvi /2023Dt.:- 19/ 01/2024

TEST RESULTS

Issued To : M/S Mount Carmel School, Adegaon, Arvi	
Samp. Received Letter Date : 19 / 01/2024 Sample Inward No.1/SDL/GSDA/ARVI/ Inward Date : 19/01/2024 Sample Name / Category : Water	Chemical Analysis Start : // Chemical Analysis End : / Bacteriological Analysis Start : 19/01/2024 Bacteriological Analysis End : 23/01/2024
Sample Source :- Boarwell No. of Sample :- 01	Quantity Received (for chem.): Quantity Received (for Bact.) :- 100ml
Sample Collected by - Applicant	Sampling Location : Mount Carmel School, Adegaon, Arvi

Sr. No.	Test Parameter	Measurement Unit	Requirement as per IS 10500 : 2012 (Drinking Water Specifications)		Test Result
			Desirable Limit	Permissible Limit	
CHEMICAL TEST -					
1.	Colour	-	-	-	0
2.	Odour	-	-	-	0
3.	Temperature	°C	-	-	0
4.	Turbidity	NTU	-	-	0
5.	pH		6.5 TO 8.5	No Relaxation	0
6.	Electrical Conductivity	uS/cm	-	-	0
7.	TDS	mg/L	500	2000	0
8.	Total Hardness	mg/L	200	600	0
9.	Fluoride	mg/L	1	1.5	0
10.	Nitrate	mg/L	45	-	0
11.	Iron	mg/L	0.3	1.0	0
12.	Sulphate	mg/L	200	400	0
13.	Total Alkalinity	mg/L	200	600	0
14.	Chloride	mg/L	250	1000	0
BACTERIOLOGICAL TEST -					
15.	Total Coliform	MPN/100 ml	0	0	0
16.	E.Coli	MPN/100 ml	0	0	0

Remarks :

- The results are as per sample provided by applicant.
- The report shall not be reproduced except in full, without the written approval of the laboratory.
- The Sample is collected by the client himself. As such the lab has no involvement in sample collection.
- This report should not be used for commercial purpose.
- For drinking purpose water sample should be tested regularly.

Chemist/Bacteriologist
SDL Arvi

MANAGER

Chemist
Monitoring Cell, GSDA Wardha

MOUNT CARMEL CONVENT SCHOOL
ADEGAON, TAH. ARVI, DIST. WARDHA (M.S.) 44220

MOUNT CARMEL CONVENT SCHOOL
ADEGAON, TAH. ARVI, DIST. WARDHA (M.S.) 44220